

**Addendum 1**  
**To RFP 22-1005 for Concrete Floors Resealing and Resurfacing**  
**Questions, Answers, and Revisions**

RFI #	Question	Answer
1.	Are there any concerns with the joints? Will any caulking be required?	No.
2.	Will there be any work outside of the exhibit halls for this project?	No.
3.	What causes the floors to rust?	There are metallic filaments in the finish that rust when water sits for any length of time. We want to use a finish that won't rust.
4.	What do you currently clean the floor with?	Fusion BG for removing the tape residue and Spartan SB-130 for cleaning the floor.
5.	If all exhibit halls are awarded, will you want one matching color/tone for all halls?	Yes.
6.	If existing cracks become bigger with resurfacing, will those cracks need to be patched/sealed?	No.
7.	What is the schedule/timeline for this project? When will it need to be completed by?	Schedule will be determined by event activity. Awarded Contractor will need to work around event activity.
8.	Will the columns need any resealing/resurfacing work?	No.
9.	What is the prevailing wage determination?	SC-23-203-2-2020-1.

**Revisions**

After further evaluation, the San Diego Convention Center Corporation has decided to revise the bidding format to remove the proposed allowance for resealing and resurfacing specific areas of halls. Bidding will now be for full wall to wall pricing for each hall individually for Halls A-H, as well as a discounted rate (if applicable) for being awarded all halls. The resurfacing and resealing scope of work remains unchanged. Please submit bids on: Exhibit B – Revised Bid Form – RFP 22-1005.