Addendum 1 To RFQ 21-1004 for Design-Build – West Building Roof Renovation Questions and Answers

Issued on March 15, 2021

| Question | Answer |
|------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| What is the square footage of the roof? | The EPDM portion of the west building roof is approximately 108,000 square feet. This does not include the square footage of the tennis court removal intended to be within the scope of this project. During the subsequent Request for Proposal phase, the shortlisted bidders will have the opportunity to access the site as needed for inspection and field measurements. It will be the bidders' responsibility to ensure the accuracy of all measurements prior to submission of their proposal. |
| What type of roof is currently in place? | The original west building roof is comprised of upper and lower roof sections covered with low slope ballasted EPDM roof systems. |