

Addendum 2
To RFP 23-1011 for Sewer Ejector Pump Replacement
Revisions and Clarifications

Issued on June 20, 2022

RFI #	Question/RFI	Answer/Clarification
1.	Is the contractor responsible for providing a temporary storage tank during the work?	Yes.
2.	What are the sewer loads?	See page 7 of the RFP under Scope of Work: Project Scope (ii).
3.	Will the San Diego Convention Center Corporation provide the floats in addition to the pumps?	No. See page 7 of the RFP under Scope of Work: Project Scope (v).
4.	What means and methods would be required for removal of the concrete membrane/coating? Could it be removed by pressure washing?	Assume coating is mostly removable by pressure washing.
5.	Where is the endpoint of the sewer pipe scope?	Endpoint of sewer pipe scope is at the connection point to the main sewer line.
6.	What size does the replacement sewer pipe need to be?	See page 7 of the RFP under Scope of Work: Project Scope (iv).
7.	Who is responsible for providing equipment to lift the pumps out?	The contractor is responsible for providing equipment to lift pumps out.
8.	What is the distance from the electrical box to the CO panel?	Assume 125 feet from panel to panel.
9.	What are the height limitations for vehicles that need access to the pump area?	9'- 6/12".
10.	What is the distance between where the pump truck can park and the pumps?	50 feet maximum.
11.	Will the contractor be provided with parking when working on the job?	The San Diego Convention Center Corporation will make every attempt to provide the contractor with parking at the loading docks.
12.	Are there panel spares?	Assume panel spares are available at CO panel.

All RFP documents and exhibits are available for download at: [RFP 23-1011 Sewer Ejector Pump Replacement - San Diego Convention Center \(visitsandiego.com\)](https://visitsandiego.com/rfp-23-1011-sewer-ejector-pump-replacement)