

Addendum 3
To RFP 23-1011 for Sewer Ejector Pump Replacement
Revisions and Clarifications

Issued on June 23, 2022

RFI #	Question/RFI	Answer/Clarification
1.	Is there any conduit work for local alarm and trough to security office to run the alarm wire?	The base scope includes providing a localized audible and visual alarm system. The San Diego Convention Center Corporation (“Corporation”) is relying on local expertise to provide an add alternate for a system that alarms to the security office located on the ground floor from the sewer ejector pump. A localized alarm system is already in place at the San Diego Convention Center which is centrally accessed at the security office. This adder work would include any required coordination, design, conduit work, controls work, and cable runs necessary to provide the complete system. For bidding purposes, assume this add alternate would require a cable run to no further than the CO panel shown during the site walk, however, other panels may be used if an approved design calls for it. This connection to the existing system would need to be evaluated and designed prior to install. Note that any proposed system, design, and drawings would require separate approval from Corporation prior to installation.

All RFP documents and exhibits are available for download at: [RFP 23-1011 Sewer Ejector Pump Replacement - San Diego Convention Center \(visitsandiego.com\)](https://visitsandiego.com/rfp-23-1011-sewer-ejector-pump-replacement)